


BI15U-EM30WD-AP6X-H1141/3GD Inductive Sensor - For the Food Industry




Technical data

Туре	BI15U-EM30WD-AP6X-H1141/3GD	
ID	1634855	
General data		
Rated switching distance	15 mm	
Mounting conditions	Flush	
Secured operating distance	≤ (0.81 × Sn) mm	
Repeat accuracy	≤ 2 % of full scale	
Temperature drift	≤ ±10 %	
	≤ ± 20 %, ≤ -25 °C , ≥ +70 °C	
Hysteresis	315 %	
Electrical data		
Operating voltage U _в	1030 VDC	
Ripple U _{ss}	≤ 10 % U _{Bmax}	
DC rated operating current I _e	≤ 200 mA	
No-load current	≤ 25 mA	
Residual current	≤ 0.1 mA	
Isolation test voltage	0.5 kV	
Short-circuit protection	yes/Cyclic	
Voltage drop at I _e	≤ 1.8 V	
Wire break/reverse polarity protection	yes/Complete	
Output function	3-wire, NO contact, PNP	
DC field stability	300 mT	
AC field stability	300 mT _{ss}	
Insulation class		


Features

- ■Threaded barrel, M30 x 1.5
- Stainless steel, 1.4404
- Front cap made of liquid crystal polymer
- Factor 1 for all metals
- Resistant to magnetic fields
- ■For temperatures of -40 °C...+100 °C
- High protection class IP69K for harsh environments
- Special double-lip seal
- ■Protection against all common acidic and alkaline cleaning agents
- Laser engraved label, permanently legible
- ■DC 3-wire, 10...30 VDC
- ■NO contact, PNP output
- ■M12 x 1 male connector
- ■ATEX category II 3 G, Ex zone 2
- ■ATEX category II 3 D, Ex zone 22

Wiring diagram











Switching frequency	0.75 kHz		
Approval acc. to	ATEX test certificate TURCK Ex-10002M X		
Device marking	EX II 3 G Ex ec IIC T4 Gc/II 3 D Ex tc IIIC T110 °C Dc		
Warning	Do not unplug connector under voltage		
Mechanical data			
Design	Threaded barrel, M30 x 1.5		
Dimensions	62 mm		
Housing material	Stainless steel, 1.4404 (AISI 316L)		
Active area material	Plastic, LCP		
Connector housing	plastic, PP		
Admissible pressure on front cap	≤ 10 bar		
Max. tightening torque of housing nut	75 Nm		
Electrical connection	Connector, M12 × 1		
Environmental conditions			
Ambient temperature	-40+100 °C		
	For explosion hazardous areas see instruction leaflet		
Vibration resistance	55 Hz (1 mm)		
Shock resistance	30 g (11 ms)		
Protection class	IP68 IP69K		
MTTF	874 years acc. to SN 29500 (Ed. 99) 40 °C		
Switching state	LED, Yellow		
Included in delivery	SC-M12/3GD		

Mounting instructions


Mounting instructions/Description





Distance D	60 mm
Distance W	3 x Sn
Distance T	3 x B
Distance S	1.5 x B
Distance G	6 x Sn
Diameter active area B	Ø 30 mm

All flush mountable uprox+ threaded barrel types are also recessed mountable. Safe operation is ensured if the sensor is screwed in by half a turn.




Accessories

MW30

30,5 11,2 34,8 57,2 12,6 44,5

6945005

Mounting bracket for threaded barrel sensors; material: Stainless steel A2 1.4301 (AISI 304)



BSS-30


6901319

Mounting clamp for smooth and threaded barrel sensors; material: Polypropylene

PN-M30

6905308

Protective nut for M30 x 1 threaded barrel devices; material: Stainless steel A2 1.4305 (AISI 303)



Wiring accessories

Dimension drawing	Туре	ID	
M12×1 14 14 14 14 14 14 14 14 14 14 14 14 14	RKH4-2/TFE	6935482	Connection cable, M12 female connector, straight, 3-pin, stainless steel coupling nut, cable length: 2 m, jacket material: PVC, gray; temperature range: -25+80 °C
M12×1 1/2 14	RKH4-2/TFG	6934384	Connection cable, M12 female connector, straight, 3-pin, stainless steel coupling nut, cable length: 2 m, jacket material: TPE, gray; temperature range: -40+105 °C



Instructions for use

Intended use

This device fulfills the directive 2014/34/EU and is suited for use in explosion-hazardous areas acc. to EN60079-0:2018, EN60079-7:2015/A1:2018, EN60079-31:2014.In order to ensure correct operation to the intended purpose it is required to observe the national regulations and directives.

For use in explosion hazardous areas conform to classification

II 3 G and II 3 D (Group II, Category 3 G, electrical equipment for gaseous atmospheres and category 3 D, electrical equipment for dust atmospheres).

Marking (see device or technical data sheet)

Local admissible ambient temperature

-25...+70 °C

Installation/Commissioning

These devices may only be installed, connected and operated by trained and qualified staff. Qualified staff must have knowledge of protection classes, directives and regulations concerning electrical equipment designed for use in explosion hazardous areas. Please verify that the classification and the marking on the device comply with the actual application conditions.

Installation and mounting instructions

Avoid static charging of cables and plastic devices. Please only clean the device with a damp cloth. Do not install the device in a dust flow and avoid build-up of dust deposits on the device. The devices must be protected against strong magnetic fields. The pin configuration and the electrical specifications can be taken from the device marking or the technical data sheet. In order to avoid contamination of the device, please remove possible blanking plugs of the cable glands or connectors only shortly before inserting the cable or opening the cable socket.

Special conditions for safe operation

For devices with M12 connectors please use the supplied safety clip SC-M12/3GD.Do not disconnect the plug-in connection or cable under voltage.Please attach a warning label permanently in an appropriate fashion in close proximity to the plug-in connection with the following inscription: Nicht unter Spannung trennen / Do not separate when energized.The device must be protected against any kind of mechanical damage and degrading UV-radiation.The IP protection rating of the connectors is given only in combination with a suitable O-ringLoad voltage and operating voltage of this equipment must be supplied from power supplies with safe isolation (IEC 30 364/UL508), to ensure that the rated voltage of the equipment (24 VDC +20% = 28.8 VDC) is never exceeded by more than 40%.

Service/Maintenance

Repairs are not possible. The approval expires if the device is repaired or modified by a person other than the manufacturer. The most important data from the approval are listed.